

FU

Series
Controller

FU400/48
FU72
FU86
FU96

Upgraded FU Series Digital PID Temperature Controller



TAIE

TAIWAN INSTRUMENT & CONTROL CO., LTD


Classical Re-evolution

Double Loop

Precise Control

High Reliability

High Accuracy ±0.1%



Sampling Time 50ms

Speed upper to
115200 bps

Excellent Anti-Interference Ability

Adopt new anti-interference algorithm and pass the highest level of EMC verification in CE certification. It can resist electromagnetic interference in heavy noise environment.



IP65 Proof

IP65 dust & water proof is available for all models (optional function).



High Speed Sampling and High Accuracy

Both loops can perform high-speed sampling for 50ms, enabling stable control and response. Built-in 18-bit high resolution ADC circuit provides up to 0.1% accuracy.



Customize Function Key

It can be quickly executed the event by A/M key.
Ex: auto/manual switch, run/stop switch etc.




Status Indicator Light

Real time monitor the status of output(OUT1/OUT2)、alarm(AL1/AL2/AL3),auto-tunning(AT),manual output(MAN) and program execute(PRO).



Autotuning(AT)

AT Function can calculate the optimize PID value for your control system, without trying.




Bar-Graph

The output percentage is directly displayed on the panel with a bar-graph indicator 10 LED's corresponding to every 10% differential in output (0~100%) (except NFU400/NFU48).




Function block diagram






Features

Various I/O Types





Excellent Control Performance



Powerful Program Control


Provides 18 patterns of 8 segments of program control, each segment can be arbitrarily set to ramp, soak ,step or cool down temperature, the user can be arbitrary according to the demand, the maximum can support to 144 segments program control.



Features


Double Loop Control

Double Loop design, accept two sensor inputs at the same time, independently control two systems, effectively reduce system costs.



Motor Valve Control

Can use position feedback control of valve opening input or servo control without valve opening input.




Transmission

Transfer parameter digital values as analog signals to external devices.

signals : 0~20mA , 4~20mA , 0~5V , 1~5V ,
0~10V ...


parameters : SV1, PV1,MV1...



Remote SV

SV value is controlled by an analog signal from an external device.

signals : 0~20mA , 4~20mA , 0~5V , 1~5V , 0~10V ...
parameters : SV




Communication

Compatible with Modbus RTU communication protocol to quickly establish links with HMI, PLC or SCADA software.




Heater Break Alarm(HBA)

With a CT (current transformer) to monitor the heater current in real time, when the current value is abnormally reduced an alarm signal can be output to notify the user.




Appearance


FU48/400



FU72



FU86




FU96




NO.	NAME	Function	NO.	NAME	Function
1	PV	Indicates PV (measured value) and character information such as parameter codes and error codes (Red)	9	OUT2	Lamp lit when OUT2 is activated (Green)
2	SV	Indicates SV (target set value) and parameter Values (Green)	10	AT	Lamp lit when Auto-tuning is activated (Orange)
3	SET	Used for parameter calling up and set value registration	11	AL1	Lamp lit when Alarm 1 is activated (Red)
4	A/M	Auto/manual switch or others function start	12	AL2	Lamp lit when Alarm 2 is activated (Red)
5	<	Shift digits when settings are changed	13	AL3	Lamp lit when Alarm 3 is activated (Red)
6	▽	Decrease Key (-1000,-100,-10,-1)	14	MAN	Lamp lit when controller in manual mode or get error condition (Orange)
7	△	Increase Key (+1000,+100,+10,+1)	15	PRO	Lights when program running (Orange)
8	OUT1	Lamp lit when OUT1 is activated (Green)	16	OUT%	Output percentage (Green)

External and Panel Cutout Dimensions




Terminal Arrangement


FU400/FU48




FU72



FU86



FU96



Power	1 L AC 85~265V 2 N 6 DC 24V 11 T/R (B) 12 T/R (A)	Communication	Remote/CT Input
Output-1	4 Relay 5 SSR 4 mA/V	1 Φ Zero cross	TRS
Output-2	2 Relay 3 SSR 2 mA/V		
Alarm-1 Alarm-2	2 AL1 or 11 3 AL2 12 13 14	Motor valve	Input
Power	1 L AC 85~265V 2 N 1 DC 24V 2 mA/V	Alarm-1 Alarm-2 Alarm-3	CTInput
Output-1	5 NO 6 NC 7 COM 8 mA/V	Communication	1 Φ Zerocross Phaseangle
Output-2	3 Relay 4 SSR 3 mA/V		
Motor valve	3 CLOSE 4 OPEN 5 COM 6 mA/V	TRS	
Power	1 L AC 85~265V 2 N 1 DC 24V 2 mA/V	Remote	Input
Output-1	8 NO 9 NC 10 COM 9 mA/V		
Output-2	6 Relay 7 SSR 6 mA/V		
Motor valve	7 CLOSE 8 OPEN 9 COM 8 mA/V		
Power	1 L AC 85~265V 2 N 1 DC 24V 2 mA/V	Motor valve	TRS
Output-1	8 NO 9 NC 10 COM 9 mA/V	Alarm-1 Alarm-2 Alarm-3	Remote/CT Input
Output-2	6 Relay 7 SSR 6 mA/V	Communication	Input-1
Power	1 L AC 85~265V 2 N 1 DC 24V 2 mA/V		
Output-1	8 NO 9 NC 10 COM 9 mA/V		
Output-2	6 Relay 7 SSR 6 mA/V		
Motor valve	7 CLOSE 8 OPEN 9 COM 8 mA/V		
Power	1 L AC 85~265V 2 N 1 DC 24V 2 mA/V	Alarm-1 Alarm-2 Alarm-3	Input-1
Output-1	8 NO 9 NC 10 COM 9 mA/V	Communication	1 Φ / 3 Φ Zero cross
Output-2	6 Relay 7 SSR 6 mA/V	TRS	
Motor valve	8 CLOSE 9 OPEN 10 COM 8 mA/V	Remote/CT Input	1 Φ Phase angle

Specifications

Standard Spec.	
Supply voltage	AC 85 ~ 265V DC 24V ±10%
Power Consumption	AC approx. 6VA DC approx. 4W
Memory	Non-volatile memory Maximum writes : 1000,000 times Data retention : 10 years
Operating temperature	0~50°C (32~122°F)
Humidity range	20% ~ 90% RH
Weight	FU400/48 approx. 120g FU72 approx. 150g FU86 approx. 170g FU96 approx. 230g
Dimension (mm)	FU400/48 48W X 48H X 95.5L (1/16 DIN) FU72 72W X 72H X 95.5L (3/16 DIN) FU86 48W X 96H X 95.5L (1/8 DIN) FU96 96W X 96H X 95.5L (1/4 DIN)
Operating environment	Non-corrosive, flammable gas, slight dust ring environment, no high frequency, no direct shock, places the sun is not directly exposed.
Input	
Accuracy	Cold junction compensation diode external ±(0.1% of reading + 1 digit) Cold junction compensation diode inside ±(0.3% of reading + 1 digit)
Sampling time	50ms
TC	K、J、R、S、B、E、N、T、W、PLII、L
RTD	PT100
mA dc	0~5V、0~10V、0~2V、1~5V 2~10V、0~25mV、0~50mV、 0~20mA、4~20mA、0~1V、 10~50mV、0~70mV
Input filter	First-order low-pass filter Time constant : 0.1 to 10.0 sec.(When set to 0, the filter is off)
PV compensation	Both zero and high points can be compensated
Output	
Set	Maximum 2 sets
Control	1.PID, P, PI, and PD control (including AT function) 2.ON/OFF control 3.Heat and Cooling PID control (including AT function)
Relay	1.SPST-NO, 250VAC, 5A Electrical life : 100,000 times 2.SPDT-NO, 250VAC, 5A Electrical life : 50,000 times 3.SPDT-NC, 250VAC, 2A Electrical life : 20,000 times
SSR	ON : 24 V OFF: 0V Maximum load current : 20mA With short circuit protection circuit
mA	Resolution: 10 bits Signal type: 4~20mA, 0~20mA, 0~5V, 0~10V, 1~5V, 2~10V

Heater Break Alarm (HBA)	
CT model	SC-80T, SC-100T
Maximum current	SC-80T : 80A, SC-100T : 100A
Accuracy	SC-80T : ±3%, SC-100T : ±5%
Aperture	SC-80T : 5.9mm, SC-100T : 12.6mm
Output	Free load alarm 1~3
Alarm	
Set	Maximum 3 sets
Mode	Program end, System error, HBA, Soak timer, Deviation high, Deviation low, Band, Process high, Process low, Program run, System normal, Ramp Soak Timer, Timer, Counter, 24H Timer
Relay specifications (resistive load)	1.SPST-NO, 250VAC, 5A Electrical life: 100,000 times 2.SPDT-NO, 250VAC, 5A Electrical life: 50,000 timers 3.SPDT-NC, 250VAC, 2A Electrical life: 20,000 times
Transmission	
set	1 set
Resolution	14 bits
Accuracy	0.1%
Parameters	PV、SV
Signal Type	4~20mA, 0~20mA, 0~5V, 0~10V, 1~5V, 2~10V
Remote	
set	1 set
Resolution	18 bits
Parameters	Local SV
Signal Type	4~20mA, 0~20mA, 0~5V, 0~10V, 1~5V, 2~10V
Motor Valve	
set	1 set
Resolution	18 bits
Parameters	PV2
Signal Type	1KΩ or 560Ω
Communication	
Communication	RS-485
Protocol	Modbus RTU, TAIE
Baud rate	2400, 4800, 9600, 19200, 38400, 57600, 115200 bps
Communication format configuration	1. Starting bit : 1 2. Information bits : 8 3. Bit check : None, Odd, Even 4. Stop bits : 1 or 2
Responses time	0~250ms
Maximum connections	31pcs

Order Information

Block means optional functions with additional charge

Input Type Table

TYPE	Thermocouple												RTD				
	K	J	R	S	B	E	N	T	W	PLII	L	PT100					
Kind	K1	K2	J1	J2	R	S	B	E	N	T1	T2	W	PLII	L	DP1	DP2	DP3
Code	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17
Range °C	600.0	1200	400.0	1200	-50	-50	1760	1760	900	400.0	400	1300	2320	800	850.0	850	850
	-50.0	-50	-50.0	-50	-50	-50	-50	-50	-50	-199.9	-199	-50	-50	-50	-199.9	-199	0



Before operating this product, read the instruction manual carefully to avoid incorrect operation.

This product is intended for use with industrial machines, test and measuring equipment.

It is not design for use with medical equipment.

If it is possible that an accident may occur as a result of the failure of the product or some other abnormality, an appropriate independent protection device must be installed.